

DIRECTIONS FOR USE:

This product must be used in accordance to the following directions by HVACR professionals only.

Apply a uniform coating liberally on the surfaces wherever leaks are suspected. Visually examine surfaces for signs of foam or small bubble formation. Be patient - wait a minimum of 5 minutes. Check bottom of all fittings for increased bubbles/foam. If a leak is found in a refrigeration system, consider Nu-Calgon's EasySeal if the situation is appropriate.

NOT FOR USE ON OXYGEN SYSTEMS.

Authorized by the U.S.D.A. for use in federally inspected meat and poultry plants.



Made in the U.S.A. • Nu-Calgon
2611 Schuetz Rd. • St. Louis, MO 63043
Customer Service: 800-554-5499
Chemical Emergency: 800-424-9300
www.nucalgon.com
(318) Calgon is a licensed trade name.

Nu-Calgon

4832-C9

Gas Leak Detector

MICRO GAS LEAK DETECTOR

Non-Freezing

High Viscosity Formulation

Non-Corrosive

FOR PROFESSIONAL USE ONLY

6 fl. oz. (177mL)

WARNING

Flammable liquid and vapor. Causes serious eye irritation. Suspected of causing cancer.

PREVENTION: Keep away from heat, hot surfaces, sparks, open flames and other ignition sources. No smoking. Keep container tightly closed. Ground and bond container and receiving equipment. Use explosion-proof electrical/ventilating/lighting equipment. Use non-sparking tools. Take action to prevent static discharges. Wash thoroughly after handling. Obtain special instructions before use. Do not handle until all safety precautions have been read and understood. Wear protective gloves/protective clothing/eye protection/face protection.

RESPONSE: In case of fire: Use appropriate media to extinguish. **IF ON SKIN (or hair):** Take off immediately all contaminated clothing. Rinse skin with water or shower. **IF IN EYES:** Rinse cautiously with water for several minutes. Remove contact lenses, if present and easy to do. Continue rinsing. If eye irritation persists: Get medical advice/attention. IF exposed or concerned: Get medical advice/attention.

STORAGE: Store in a well-ventilated place. Keep cool. Store locked up.

DISPOSAL: Dispose of contents/container in accordance with local/regional/national/international regulations.



ATTENTION

Liquide et vapeur inflammables. Provoque une sévère irritation des yeux. Susceptible de provoquer le cancer.

PRÉVENTION : Tenir loin de la chaleur, des surfaces chaudes, des étincelles, des flammes nues et autres sources d'inflammation. Défense de fumer. Tenir le récipient bien fermé. Mise à la terre et liaison équipotentielle du récipient et du matériel de réception. Utiliser du matériel électrique/de ventilation/d'éclairage antidéflagrant. Utiliser des outils ne produisant pas des étincelles. Prendre des mesures contre les décharges électrostatiques. Se laver soigneusement après la manipulation. Se procurer les instructions avant utilisation. Ne pas manipuler avant d'avoir lu et compris toutes les mesures de sécurité. Porter des gants/vêtements de protection/ équipement de protection des yeux/du visage.

INTERVENTION : En cas d'incendie : utiliser un agent d'extinction approprié. **EN CAS DE CONTACT AVEC LA PEAU (ou les cheveux) :** Enlever immédiatement tous les vêtements contaminés. Rincer la peau à l'eau ou se doucher. **EN CAS DE CONTACT AVEC LES YEUX :** Rincer avec précaution à l'eau pendant plusieurs minutes. Enlever les lentilles de contact si la victime en porte et si elles peuvent être facilement enlevées. Continuer à rincer. Si l'irritation des yeux persiste: Demander un conseil médical/des soins. Si exposé(e) ou préoccupé(e) : Obtenir une consultation médicale ou des soins médicaux.

STOCKAGE : Stocker dans un endroit bien ventilé. Conserver au frais. Garder sous clef.

ÉLIMINATION : Éliminer le contenu/les conteneurs selon la loi internationale/nationale/régionale/locale.

