

DIRECTIONS FOR USE:

This product must be used in accordance to the following directions by HVACR professionals only.

Apply a uniform coating liberally on the surfaces wherever leaks are suspected. Visually examine surfaces for signs of foam or small bubble formation. Be patient - wait a minimum of 5 minutes. Check bottom of all fittings for increased bubbles/foam. If a leak is found in a refrigeration system, consider Nu-Calgon's EasySeal if the situation is appropriate.

NOT FOR USE ON OXYGEN SYSTEMS.

⚠️WARNING: This product can expose you to chemicals including diethanolamine, which is known to the State of California to cause cancer, and methanol, which is known to the State of California to cause birth defects or other reproductive harm. For more information go to www.P65Warnings.ca.gov.



Made in the U.S.A. • Nu-Calgon
2611 Schuetz Rd. • St. Louis, MO 63043
Customer Service: 800-554-5499
Chemical Emergency: 800-424-9300
www.nucalgon.com
(0922) Calgon is a licensed trade name.

4180-53

Gas Leak Detector

MICRO GAS LEAK DETECTOR

Non-Freezing

High Viscosity Formulation

Non-Corrosive

FOR PROFESSIONAL USE ONLY

**WARNING**

Flammable liquid and vapor. Causes serious eye irritation. Suspected of causing cancer.

PREVENTION: Obtain special instructions before use. Do not handle until all safety precautions have been read and understood. Keep away from heat, hot surfaces, sparks, open flames and other ignition sources. No smoking. Keep container tightly closed. Ground and bond container and receiving equipment. Use explosion-proof electrical, ventilating and lighting equipment. Use non-sparking tools. Take action to prevent static discharges. Wash thoroughly after handling. Wear protective gloves, protective clothing, eye protection and face protection.

RESPONSE: IF ON SKIN (or hair): Take off immediately all contaminated clothing. Rinse skin with water or shower. **IF IN EYES:** Rinse cautiously with water for several minutes. Remove contact lenses, if present and easy to do. Continue rinsing. If eye irritation persists: Get medical attention. IF exposed or concerned: Get medical attention. In case of fire: Use appropriate media to extinguish.

STORAGE: Store in a well-ventilated place. Keep cool. Store locked up. **DISPOSAL:** Dispose of container in accordance with local, regional, national and international regulations.

KEEP OUT OF REACH OF CHILDREN

CONTAINS (CAS#): Diethanolamine (111-42-2), Glycerol (56-81-5), Isopropanol (67-63-0).

6 fl. oz. (177mL)