ClenAir by Nu-Calgon

Breathe Easy With ClenAir!

PART# CA10

Universal Replacement Panel

Humidifier Panel™

110
- Turn off and disconnect electric and water supply
- Turn 2 latches on both sides and slip off 3 clamps. Now you're ready to remove upper cover by lifting up and out.
- Remove and discard old humidifier panel and clean any lime deposits.
- Replace with your new humidifier panel. IMPORTANT: mark on pad must be up!
- Reassemble unit and reconnect water and electric

220
- Turn off and disconnect electric and water supply
- Disconnect top half of your humidifier from your furnace plenum by removing 3 clips.
- Unscrew compression fitting on water line and slide 4 clamps from cover of humidifier.
- Remove 2 screws and lift cover straight up.
- Remove and discard old humidifier panel and clean any lime deposits.
- Replace with your new humidifier panel. IMPORTANT: mark on pad must be up!
- Reassemble unit and reconnect water and electric

550 & Other Brands
- Turn off and disconnect electric and water supply
- Remove cover from humidifier. Remove water supply tube from tray at top of panel. Now you're ready to tip your panel forward. Lift white tabs at each side of the black tray.
- Remove and discard old humidifier panel and clean any lime deposits.
- Replace with your new humidifier panel. IMPORTANT: mark on pad must be up!
- Reassemble unit and reconnect water and electric

For best performance, change at least once per season, maybe more depending on water conditions and frequency of use.
WARNING: Turn off and disconnect electric water supplies to prevent electrical shock
For cleaning water line, refer to the owner's manual for your humidifier.
Always insert your new humidifier panel with mark on top! DO NOT scratch or scrape the top water distribution tray. This coating is required for proper water distribution.

FOR USE WITH THESE HUMIDIFIER MODELS:

APRILAIRE®
110, 220, 500, 500A, 500M, 550, 550A, 558

CHIPPEWA® 220

BRYANT®
HUMBBSBP2212, HUMBBSBP2312, HUMBASBP2312, HUMBBSBP2412, HUMBASBP2412

CARRIER®
HUMCCSBP2212, HUMCCSBP2312, HUMCASBP2312, HUMCCSBP2412, HUMCASBP2412

HAMILTON®
12HF

HONEYWELL®
HE220A/B, HE225A/B

LASKO®
5000L, 5000EC, 6000

LENNOX®
WB2-12, WB2-12A

HEALTHY CLIMATE®
HCWB2-12, HCWB2-12A

TOTALINE®
P110-SBP2212, P110-SBP2312, P110-SBP2412

Note: Insert with colored spot up. For peak performance, change once a year using only ClenAir Replacement Pads.

MADE IN THE USA

All company names and tradenames herein listed are registered tradenames of their respective companies. ClenAir Mfg. Inc. is an independent company and is not related to or affiliated with these companies.

7 45310 20010 7

SATISFACTION ClenAir QUALITY GUARANTEED